FIRE PREVENTION
MOBILE FOOD VENDING CHECKLIST

DATE: _____ PERMIT #: _____

Applicant/Owner: _____

Address: _____
Street City State Bldg/Ste. Zip Code

Contact Phone: _____ Vehicle License Number _____

☐ Propane ☐ Generator

FIRE EXTINGUISHERS: MUST HAVE CURRENT INSPECTION

- ☐ 2A10BC ☐ 3A40BC with portable generator
- ☐ K portable fire extinguisher for up to four fryers having a maximum cooking medium capacity of 80 pounds each

LPG (PROPANE):

- ☐ L.P. Gas containers shall be located and secured on the exterior of unit

***Not to be located*:** on roof vehicle, inside passenger compartment, nor can it extend further then rear bumper and is to be protected from vehicle collision

- ☐ Access must be from the exterior of the unit and compartment floor and exterior door must be vented to the atmosphere
- ☐ "NO SMOKING" sign posted with a minimum of 4 inch lettering above propane bottle
- ☐ Hose used to pipe L.P. Gas to the device must be UL or FM listed (marked 350 PSI working pressure)
- ☐ Couplings, fittings, and any other devices meet the UL or FM requirements
- ☐ LPG tanks are to be located outside the mobile unit with a minimum of 5 feet from primary means of egress

BAFFLES AND CLOSURES:

- ☐ Steel baffle between the fryer and surface flames of an adjacent appliance
- ☐ 16 inch space between fryer and surface flames from adjacent cooking equipment
- ☐ Baffle is a minimum of 8 inches in height
- ☐ Positive closing lid with latching mechanisms (Exception: fryers installed under a fixed pipe extinguishing system

EMERGENCY EGRESS:

- ☐ Clear unobstructed height over the aisle-way portion of the unit of at least 74 inches from floor to ceiling
- ☐ Minimum of 30 inches of unobstructed aisle space
- ☐ Travel distance from any portion of the interior exceed 10 feet will have a minimum of two exits
- ☐ A minimum of two exits located remote from each other
- ☐ Secondary means of egress with an unobstructed minimum passage of 24" X 24 " to the outside
- ☐ Bottom of secondary means of egress shall not be more than four (4) feet above the vehicle floor or a readily accessible
- ☐ horizontal surface capable of supporting a weight of 300 pounds minimum opening to the outside
- ☐ Secondary exit shall be labeled with the word "EXIT" with 2 inch minimum letters on contrasting background
- ☐ The latch mechanism of any exit facility shall be operable by hand

GENERATOR:

- ☐ Refueling of generators to be performed in an approved location not less than 20 feet from the mobile unit
- ☐ Fuel to be stored in a UL or FM approved flammable liquid safety container
- ☐ Storage is in an approved location (secured from movement)
- ☐ Generators shall be grounded in an approved method
- ☐ Generators shall not be refueled in areas occupied by the public

GENERAL FIRE SAFTEY :

- ☐ Installation of electrical equipment shall comply with the Electrical Codes NFPA 70 and NEC

COMMENTS: _____

_____

_____

_____

☐ Disapproved Initials: _____ Date:_____ Permit Sticker Number:_____

☐ Approved Approved By:_____ Date: _____