CITY OF SAN ANTONIO
METROPOLITAN HEALTH DISTRICT

CHLORINE RESIDUAL AND TANK SANITATION LOG SHEET

FOR THE MONTH OF:_____

Permit Number: _____

Mobile Food Establishment Name: _____

Day/Week	Test Performed	Test Results	Initials

Chlorine Residual Requirements

Minimum required 0.2 ppm chlorine (fresh water tank must be disinfected if below the minimum)

Maximum allowed 4.00 ppm chlorine (tank must be drained and refilled if above the maximum)

For further information please go to: http://www.sanantonio.gov/Health/FoodLicensing/Mobile.aspx