



CITY OF SAN ANTONIO

P. O. BOX 839966
SAN ANTONIO TEXAS 78283-3966

**TO: ALL CITIZENS OF THE CITY OF SAN ANTONIO CONCERNED WITH
ELECTRICAL CODE REGULATIONS**

RE ADOPTION NOTICE OF THE 2002 EDITION OF THE NATIONAL ELECTRIC CODE NFPA 70 WITH AN AMENDMENT TO THE EXISTING CITY CODE

This is an official notice that the Electrical Examining and Supervising Board conducted a public hearing and adopted the 2002 edition of the National Electric Code NFPA 70 at their meeting of December 10, 2002. City Council adopted an amendment to the City Code forwarded by the Electric Board on February 13, 2003 regulating the use of Non-Metallic Sheathed Cables as listed in Article 334 of the 2002 edition of the National Electric Code (NEC) NFPA 70. Below listed is the amendment to the NEC as stated in section 10-94 of the City Code regarding the use of these cables.

Section 10-94 of the City Code is hereby enacted as follows

a. Non-metallic sheathed cables shall not be used in any multifamily dwellings or other structures exceeding three floors above grade.

These provisions shall become effective Monday March 31, 2003 for all projects permitted after the effective date.

Any questions pertaining to this matter may be directed to Patrick J. Poloskey, Chief Electrical Inspector at 207-8286 or email at patrickp@sanantonio.gov.

Department of Building Inspections
February 19, 2003

PP