

New Inspection

Renewal



City of San Antonio
Fire Prevention Division
1901 S. Alamo St.
San Antonio, TX 78204

MOBILE FOOD ESTABLISHMENT INSPECTION FORM

Telephone (210) 207-8410
Fax (210) 207-7949
www.sanantonio.gov/safd



Vehicle/Trailer License Plate: _____

Date: _____

Applicant/Owner: _____

Contact Phone: _____

Mailing Address: _____
Street Bldg/Ste. City State Zip Code

- Propane w/ LP-gas alarm
- CNG w/ methane gas alarm
- Portable Generator

FIRE EXTINGUISHERS: MUST HAVE CURRENT INSPECTION (2A10BC extinguisher is the MINIMUM required extinguisher for ALL Mobile Vendor units.)

- 2A10BC
- 3A40BC w/ portable generator
- K portable fire extinguisher (up to 4 fryers w/ max. cooking oil capacity of 80 lbs each)

EXHAUST HOOD AND FIRE PROTECTION:

- Kitchen exhaust hood covering all appliances producing grease laden vapors installed and maintained
- Automatic fire extinguishing system installed and maintained for all cooking equipment

LPG (PROPANE): Maximum aggregate volume capacity shall not exceed 200 pounds

- L.P. Gas containers shall be located and secured on the exterior of unit
(*Not to be located:* on roof vehicle, inside passenger compartment, nor can it extend further than rear bumper and is to be protected from vehicle collision)
- Access must be from the exterior of the unit and compartment floor and exterior door must be vented to the atmosphere
- "NO SMOKING" sign posted with a minimum of 4 inch lettering above propane bottle
- Hose used to pipe L.P. Gas to the device must be UL or FM listed (marked 350 PSI working pressure)
- Couplings, fittings, and any other devices meet the UL or FM requirements, as outlined in NFPA 58 and 54
- LPG tanks are to be located outside the mobile unit with a minimum of 5 feet from primary means of egress

CNG: Maximum aggregate capacity shall not exceed 1300 pounds

- CNG container shall be an NGV-2 cylinder
- CNG system that supplies both the vehicle and cooking appliances must comply with NFPA 52

BAFFLES AND CLOSURES:

- Steel baffle, minimum of 8 inches in height, between the fryer and surface flames of an adjacent appliance, -OR-
- 16 inch space between fryer and surface flames from adjacent cooking equipment
- Positive closing lid with latching mechanisms (**Exception:** fryers installed under a fixed pipe extinguishing system)

EMERGENCY EGRESS:

- Clear unobstructed height over the aisle-way portion of the unit of at least 74 inches from floor to ceiling
- Minimum of 30 inches of unobstructed aisle space throughout the unit
- Travel distance from any portion of the interior exceeding 10 feet must include a minimum of 2 exits located remotely from each other
- Secondary means of egress with an unobstructed minimum passage of 24" X 24 " to the outside
- Bottom of secondary means of egress shall not be more than four (4) feet above the vehicle floor -OR- a readily accessible horizontal surface capable of supporting a weight of 300 pounds minimum opening to the outside
- Secondary exit shall be labeled with the word "EXIT" with a minimum 2 inch letters on contrasting background
- The latch mechanism on any exit shall be operable by hand from the inside of the unit

GENERATOR:

- Refueling of generators to be performed in an approved location not less than 20 feet from the mobile unit
- Fuel to be stored in a UL or FM approved flammable liquid safety container away from the mobile unit
- Storage is in an approved location (secured from movement)
- Generators shall be grounded in an approved method
- Generators shall not be refueled in areas occupied by the public

GENERAL FIRE SAFETY :

- Installation of electrical equipment shall comply with the Electrical Codes NFPA 70 and NEC

COMMENTS:

- Approved** Inspector Signature: _____ Date: _____ Permit Sticker #: _____
- Disapproved** Inspector Initials: _____ Date: _____ Permit #: _____